

875—95.11(89) Tanks. Tanks integral to a water heater that exhibit bulges or leaks shall be handled as follows:

95.11(1) If the tank does not bear an ASME stamp, it shall be removed.

95.11(2) If the tank bears an ASME stamp, it shall be removed or repaired pursuant to rule 875—91.8(89).